

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 05/12/2023

It is certified that an inspection team headed by Dr. Arun Kumar Tiwari MO CHC Sarai Akil Kaushambi (Name of Officers with designation) form MO CHC Sarai Akil Kaushambi (Name of Department / Office) inspected the D P Memorial Public School, Karan Chauraha, Sarai Akil, Kaushambi (Name & Address of the school) on 05/12/2023 (date of inspection) and found that the D P Memorial Public School (Name of school) has safe drinking water facilities for the student and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year.....

Signature with Seal

.....
चिकित्साधिकारी
स्वा. केन्द्र, सराय अकिल
कौशम्बी

Name

: Dr. Arun Kumar Tiwari

Designation

: MO CHC Sarai Akil Kaushambi

Name & Address of the Office/ Department:.....

To

D P Memorial Public School**Ghosiya, Karan Chauraha****Sarai Akil, Kaushambi, U.P.****Pin - 212216****(Name & Address of the Institution)**

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.





ALLAHABAD JAL KAL VIBHAG LABORATORY

CHEMICAL ANALYSIS OF WATER

LIST REPORT

Sr. No.

- Source of sample : Borewell, D.P. Memorial Public School Campus
- Date of sampling : Recieved 12.04.2023 From, Manager Dr. Bhisim Singh
- Date of Analysis : 12.04.2023

Physico Chemical Parameter	BIS LIMIT IS 10500:1991		Result of Test
	Requirement (Desirable Limit) mg/l	Permissible limit in the absence of alternate source mg/l	
4. Total Dissolved Solids	500	2700	392
5. Free and saline Ammonia	NS	NS	NIL
6. Albuminoid ammonia	NS	NS	NIL
7. Dissolved Oxygen	Min 5.0	NS	-
8. Hardness Total as CaCO ₂	300	600	288
(a) Temporary as CaCO ₂	NS	NA	144
(b) Permanent as CaCO ₂	NS	NS	144
9. Chlorine as Chlorides Cl	250	1000	90
10. Total Alkalinity as CaCO ₂	200	600	45
11. Nitrites as NO ₂	NS	NS	NIL
12. Nitrates as NO ₂	45	100	NIL
13. Iron as Fe	0.3	1.0	NIL
14. Fluoride s F	1.0	1.5	0.6
15. Color Hazen Unit	5	25	Colourless
16. Taste	Agreeable		Not tasted
17. Odour	Unobjectionable		Odourless
18. pH Value	6.5 to 8.5		6.8
19. Conductivity as μ mhos at 20°C	NS	NS	569
20. Turbidity NTU	5	10	1
21. Free Residual	0.2	NS	NIL
NS- Not Specified			
Remarks		Potable	-

Chemist:-
End. No.

Ex. Engg. (HQ)
Dated: Allahabad2023
जी.पी.एम. विभाग (मु.)

Copy forwarded for information to:

- The Addl. Director, State Health Institute, Sector-C, Chetan Vihar, Aliganj, Lucknow, U.P.
- Chief Medical Officer, Allahabad.
- Mukhya Nagar Swasthya Adhikari, Nagar Nigam Allahabad.
- Nagar Ayukta, Nagar Nigam Allahabad.
- The Superintending Engg. (R&D), Office of Addl. Chief Engg. (PPR & D), U.P. Jal Nigam 6, Rana Pratap Marg, Lucknow
- Chairman, Jal Kal Vibhag/Mayor, Nagar Nigam Allahabad.



ALLAHABAD JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the water taken from Bore well

Name & Designation of the person collecting the sample Dr. Bhishm Singh & Manager


Sr. No.	Date & Time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml.		Presumptive coliform count				Probable of coliform organism in 100 ml. Of original water	Free residual chlorine mg/l	Remarks
							50 ml.	10 ml.	1 ml.			
				At 37°C in 48 hours	At room temperature in 72 hours	Quantity of water put up in each tube/No. Of tubes put up	1	5	5			
							No. Of tube showing positive reaction					

12.04.23 12.04.23 — —


Borewell

D.P. Memorial Public School Campus

Karan Chauraha Saran' Aki'


Chemist







NIL Excellent

Ex. Engineer (HQ)

अधिशारी आधिकारी (मु०)

जलकल विभाग

नगर निगम, अलीगढ़